

Model	Replacement	Rated Capacity	Operating Pressure Range	Operating Temp. Range	Rated Flow
AQ-UV-10C	AQ-UV-L330C	12 months 365 days	20-100psi 137.89-689.47kPa	36-104° F 2.22-40° C	7.0 gpm 26.49 lpm
<b>Distributed by: Aquasana, Inc. 6310 Midway Road · Haltom City, Texas 76117 · 866-662-6885</b>					

Model	Replacement	Rated Capacity	Operating Pressure Range	Operating Temp. Range	Rated Flow
AQ-UV-15C	AQ-UV-L420C	12 months 365 days	20-100psi 137.89-689.47kPa	36-104° F 2.22-40° C	12.0 gpm 45.42 lpm
<b>Distributed by: Aquasana, Inc. 6310 Midway Road · Haltom City, Texas 76117 · 866-662-6885</b>					

Independently tested to NSF/ANSI Standard 55 to sterilize 99.99% of bacteria and viruses and 99% of cysts.

NSF/ANSI 55	Overall % Reduction
Cyst Live Cryptosporidium & Giardia	99%
Bacteria	99.99%
Virus	99.99%